



WATERMAIN LEGEND:

- PROPOSED WATER METER
- PROPOSED SLUICE VALVE
- PROPOSED WATERMAIN
- EXISTING SLUICE VALVE
- EXISTING WATER METER
- EXISTING WATERMAIN
- EXISTING BUILDING
- PROPOSED BUILDING
- PROPOSED SITE BOUNDARY

- NOTES:**
1. TOPOGRAPHICAL SURVEY BY MURPHY SURVEYS - DRAWING MSL23186_T_2D_ITM_Rev0 (03/11/2017).
 2. EXISTING DRAINAGE INFORMATION SUPPLIED BY IRISH WATER & DUBLIN CITY COUNCIL.
 3. ALL WATER MAIN DETAILS TO BE CONSTRUCTED IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE FOR WATER INFRASTRUCTURE & IRISH WATER STANDARD DETAILS.
 4. WATER MAIN CONNECTIONS TO BE PROVIDED TO INTERNAL DRY RISERS.
 5. ALL INTERNAL BASEMENT WATER MAINS TO M&E ENGINEERS SPECIFICATION.

Ordnance Survey Ireland Licence No EN 0003721
© Ordnance Survey Ireland/Government of Ireland

© PUNCH Consulting Engineers
This drawing and any design hereon is the copyright of the Consultants and must not be reproduced without their written consent.
All drawings remain the property of the Consultants.
Figured dimension only to be taken from this drawing.
Consultants to be informed immediately of any discrepancies before work proceeds.



Rev	Amendment	By	Date	Rev	Amendment	By	Date
C01	PLANNING ISSUE	IBS	16/03/2021				

Client: MAXOL PROPERTY LTD



Project: BEACH ROAD APARTMENT, SANDYMOUNT			
Title: PROPOSED WATERMAIN LAYOUT			
Drawn: JB	Date drawn: JB	Technician Check: JB	Engineer Check: JH
Project No: 172387	Model Ref: 172387-PUNCH-XX-XX-M2-C-0300	Approved: PC	
Scale @ A1: 1:200	Document Ref: 172387-PUNCH-XX-XX-DR-C-0300	Drawing Status: A0 PLANNING	Revision No: C01